


Hanover Sewerage Authority Notes

1. All sanitary sewer construction shall be in accordance with the Regulations, Specifications and Rate Schedule of the Hanover Sewerage Authority.
2. The property owner and contractor are responsible for providing safe working conditions. These conditions include, but are not limited to, trench safety and confined space entry. The owner / contractor shall comply with OSHA requirements for the sloping and / or shoring of trenches and excavations for entry by either construction or HSA personnel.
3. Sanitary sewer lines in the Authority's system contain a variety of domestic, commercial and industrial wastewater. Accordingly, the Authority treats all manholes and excavations with openings to the pipeline on active sewers as confined spaces. When performing work within the road right-of-way or easement, the contractor shall comply with both OSHA and HSA confined space entry requirements. In order to meet this requirement, the contractor must have, at a minimum, a Permit Required Confined Space Program meeting the requirements of 29CFR1910.146 including, but not limited to, procedures to be followed, trained employees and specialized equipment. For work performed on private property, the property owner / contractor must comply with OSHA Regulations and should consider complying with the more stringent HSA requirements.
4. Unused connections to the Authority's system shall be terminated by removing existing pipe from the tee or saddle connection on the sewer main and inserting a water tight plug. In the alternative, a short stub no more than one (1') foot in length may be inserted in the tee or saddle. This stub must be capped in a water tight manner. In either case, the cap or plug shall be encased in concrete. The area excavated adjacent to the sanitary sewer main shall be back filled with a ¾" clean stone to an elevation two (2') feet above the pipe.
5. The applicant is responsible for setting line and grade and demonstrating the required slope to the HSA Inspector.
6. The applicant is responsible for having the property surveyed and ensuring that the building sewer is on the applicants' property and the peep site is outside the road right-of-way.
7. A minimum of five (5') feet spacing is required between the building sewer and other underground utilities including but not limited to water, gas and electric.
8. Any connection proposed for re-use shall be TV inspected prior to construction and any defects shall be repaired.
9. The building sewer must pass a low pressure air test from the cleanout at the building to the peep site.
10. The building sewer must be TV inspected from the cleanout outside the building to the main prior to issuance of a TCO or CO. Pipe must be clean and any defects must be corrected.

© Mott MacDonald

THIS DOCUMENT IS ISSUED FOR THE PARTY WHICH COMMISSIONED IT AND FOR SPECIFIC PURPOSES CONNECTED WITH THE CAPTIONED PROJECT ONLY. IT SHOULD NOT BE RELIED UPON BY ANY OTHER PARTY OR USED FOR ANY OTHER PURPOSE. WE ACCEPT NO RESPONSIBILITY FOR THE CONSEQUENCES OF THIS DOCUMENT BEING RELIED UPON BY ANY OTHER PARTY, OR BEING USED FOR ANY OTHER PURPOSE, OR CONTAINING ANY ERROR OR OMISSION WHICH IS DUE TO AN ERROR OR OMISSION IN DATA SUPPLIED TO US BY OTHER PARTIES.

<p>Title</p> <p>HANOVER SEWERAGE AUTHORITY WHIPPANY, NEW JERSEY</p> <p>HANOVER SEWERAGE AUTHORITY NOTES</p>						<p>111 Wood Avenue South Iselin NJ 08830-4112 United States of America Certificate No. 24GA28016600</p> <p>T +1 (800) 832 3272 F +1 (973) 376 1072 www.mottmacamericas.com</p>			
Date	Drawn	Checked	Approved	Scale at ANSI A	Drawing Number	Status	Rev		
				NONE	D-16	PRE	REV. 1		